

Notice to Installer: Instructions must remain with installation.

ZT0288_ECb

0218

Supersedes

0617

Trusted. Tested. Tough.™



Visit our web site:
zoellerpumps.com


Product information presented here reflects conditions at time of publication. Consult factory regarding discrepancies or inconsistencies.

INSTALLATION INSTRUCTIONS

UNION CHECK VALVE

PART NO. 30-0310

- Make sure that the direction of the water flow is the same as the direction of check valve's arrow
- Can be installed in vertical or horizontal line
- Solvent weld coupling for pressure systems to 25 PSI (57' of head)



安装前务必详读说明书

Trusted. Tested. Tough.™

文件仅供参考
若有任何修改
恕不另行通知




zoellerpumps.com

安装说明书

止回阀型号. 30-0310

- 安装时，确认水流进出方向要和止回阀上标示箭头方向一致。
- 垂直或水平安装皆可。
- 额定 172 kPa (25 PSI)，17.4 m (57') 扬程。



PN 083783